



Whole House Fan In Hallway



Infrared Image



Visual Image

Voice Comment	
---------------	---

Analyses Table:

Object Parameter	Value
Max	59.7°F

Comments: Significant heat loss from fan louvers.